

SONICATED SLUDGE AS CARBON SOURCE FOR DENITRIFICATION

CASE STUDY OF FIRST AUSTRALIAN APPLICATION



Unitywater

AWA Ozwater'15 Conference, Adelaide, 12-14 May 2015

Acknowledgements

- Pedro Rojas – Unitywater Process Engineer (at time of study)
- Shaun Reynolds – Unitywater Operator-in-Charge Maroochydore STP
- Rod Wellings – Royce Water Technologies
- Dr Klaus Nickel – Ultrawaves & Technical University Hamburg-Harburg
- Luisa Magalhaes – Unitywater Grants and Innovation Specialist

Introduction

- Cost effective N removal & energy neutrality
- Maroochydore STP & trial method
- Ultrasonic WAS lysis
- Results:
 - Nitrogen removal performance
 - Decreased sludge production
 - Economic evaluation
- Conclusion

Our service area

Water and sewerage services.

Population of **700,000** people.

Geographical area of
5,223km² north of Brisbane.

From Noosa and Cooroy to
Woodford, Bribie Island,
Redcliffe and Brendale.

STPs effluent release to
coastal receiving waters.



The Need for Nitrogen Removal




- Maroochydore STP discharges into estuary
- N-limited environment
- Licence effluent total N < 3 mg/L
- Conventional nitrification-denitrification process
- Aeration → energy cost
- COD → methanol cost
- 15 day sludge age
- But compromised ability to generate biogas


Maroochydore STP




Maroochydore STP Liquid Process



Maroochydore STP Solids Process



Ultrasonic Activated Sludge Lysis



Ultrawaves Trial - one 5 kW unit




- Carbon → enhanced denitrification; no methanol
- Sonicated WAS = $25 \text{ m}^3/\text{d} \times 38 \text{ kg TSS}/\text{m}^3$

Ultrasonic Lysis Observations

- Soluble COD = 5 kg/d; Total COD = 850 kg/d
- Heterotrophic plate counts using two media:
- Yeast: Before 12×10^6 cfu/mL; After 46×10^6 cfu/mL
- R2A: Before 15×10^6 cfu/mL; After 29×10^6 cfu/mL
- Sonotrode erosion (after 15 months) → maintenance



Results: Nitrogen Removal



- Trial 50%-ile effluent total N = 1.7 mg/L
- Trial was nitrate-limited

Results: Nitrogen Removal Capacity

Nitrogen Removal Indicators	kg COD/d	kg N/d	NO ₃ -N mg/L
Effluent with no methanol and no Ultrawaves	-	57 kg/d	3.0 – 8.5 mg/L
De-aeration zone on-line nitrate analyser	-	86 kg/d	5 – 10 mg/L
Methanol use before Ultrawaves trial	304 kg/d	101 kg/d	8.8 mg/L
COD of sonicated WAS (but not 100% biodegradable)	850 kg/d	99 kg/d (max)	8.6 mg/L (max)

- N removal capacity at least 57 kg/d; up to 90 kg/d



Results: Sludge Production

Sludge Production Indicators	Baseline	Trial	Difference (%)
Mass balance VS destruction	935 kgVS/d	1075 kgVS/d	15%
Observed yield before digesters	0.47 kgVS/kgCOD	0.45 kgVS/kgCOD	4%
Observed yield after digesters	0.41 kgVS/kgCOD	0.37 kgVS/kgCOD	10%
Specific sludge prod ⁿ (relative to EP)	51 gTS/EP/d	48 gTS/EP/d	6%

- 4% COD → CO₂ and 6% COD → Biogas (incl. CH₄)



Results: Ultrawaves Costs

Cost Component	Unit Cost	Annual Cost	NPV
CAPEX - Ultrawaves units	\$176,000 / unit	4 units in 2015 +1 unit in 2021	-\$805,312
OPEX - power	120 kWh/d/unit x \$0.12/kWh	\$5,256/yr/unit	-\$223,689
OPEX - sonotrode replacement	\$2,250 x 5/unit	\$11,250/unit every 18 mth	-\$392,845
OPEX – booster shaft replacement	\$1,740 x 5/unit	\$8,700/unit every 3 yr	-\$187,300

- Ultrawaves CAPEX + OPEX NPV = -\$1,609,147

Results: Economic Evaluation

- Annual OPEX savings:
- **Methanol** = $995 \text{ L/d} \times 0.77 \text{ kg/L} \times \$640/\text{T} = \textbf{+\$178,973/yr}$ (increasing with EP growth)
- **Biosolids** = $90 \text{ kgVS/d} \times 4 \text{ units} \times 45\% \text{TS} \times \$60/\text{T} = \textbf{+ \$17,520/yr}$ (increasing with EP growth)
- Total OPEX savings NPV = **+\$2,128,017**
- Ultrawaves CAPEX + OPEX NPV = **-\$1,609,147**
- **Net Present Value = +\$518,870**
- Installation (excluded above) needs to be **<\$500,000**
- Conservative assumptions used, and more positive NPV with sensitivity analysis

Discussion

- So what do the results mean for cost effective N removal & energy neutrality
- Anaerobic reactor → Anammox → Mg/Lime P recovery are we ready?
- What about sunk capital of existing assets?
- Install primary sed tank upstream of existing bioreactors; increase capacity of existing bioreactors
- Install sonication using WAS as carbon source
- Anaerobic digesters VS destruction and biogas yield
- If primary sed tanks existing and improved N removal required, then sonication of WAS is an option

Conclusion

- First successful full-scale application in Australia of WAS sonication for enhanced denitrification
- Complete nitrate removal was achieved during the trial and N removal capacity was at least 57 kg/d
- Sludge production was decreased by 100 kg/d
- Economic evaluation showed that the OPEX savings, especially for methanol, resulted in a positive NPV
- WAS sonication technology opens options to:
 - Increase bioreactor capacity with primary sed tank
 - Achieve N removal in COD-limited bioreactors
 - Decrease sludge production and increase biogas



Thank you
Questions ?



Unitywater